

**SEMINOLE COUNTY - PURCHASING AND CONTRACTS DIVISION
EMERGENCY PURCHASE DATA SHEET**

Date Requested: June 13, 2019

Requisition No.: _____

Requestor: Joe Routt

Telephone/Ext.: 407-665-5262

Department/Division: Public Works Department / Fleet

Describe the Emergency: Public Safety Building appears to have taken a lightning strike that had hindered the generator PLC/Controller. Without this PLC/Controller at 100%, the generators cannot sense when power to the building has been restored. Being this building houses Emergency Operations, 911 Center, 5100 Center, Sheriff Operations & Forensics, it is imperative we have this replaced immediately. Attached is the quote provided by Genset Services, Inc. to repair / replace the damaged material. We selected this company based on their intimate familiarity with our generators, transfer switch, PLC, and controllers.

Does the emergency fit the definition as described in Section 220.4? Yes X No _____

Describe the harm / impact of the emergency: As the PLC/Controller is currently unstable, any false inputs/outputs of this controller threatens the reliability of the backup generators.

Companies contacted and their quotes:

Company: Genset Services, Inc. (Repairs) Contact/Phone: _____ Cost: \$ 335,196.00

Company: Genset Services, Inc. (5-Month Rental) Contact/Phone: _____ Cost: \$ 147,000.00

Total: 482,196.00

Approval from the Department Requesting Emergency:

Requesting Division Manager Signature: 

Requesting Department Director Signature: _____

Purchasing and Contracts Division Approval:

Purchasing Review and Approval: _____ Date: _____

Purchase Order No.: _____ Amount of Purchase: \$ _____